



## SUPPLEMENTAL/BID BULLETIN

### BID BULLETIN NO. 01 29 September 2020

Name of Project: **Supply, Delivery, Installation, Test and Commissioning of One (1) Unit Diesel Generator Set System Including its Ancillaries and/or Accessories with Rehabilitation of Generator and Switchgear Rooms of TESDA Central Office Main Building**

Approved Budget for the Contract: **₱3,788,177.04**

During the pre-bid conference held on 24 September 2020 and pursuant to Section 22.5 of the 2016 Revised Implementing Rules and Regulations of Republic Act No. 9184, the following queries or request for clarification of the prospective bidders are hereby clarified:

#### 1. Integrated Power & Control Provider

<b>REQUIREMENT</b>	No. 2 of the Requirements of a Service Provider under Section VI of the Bidding Documents  <i>Must possess an active Philippine Construction Accreditation Board (PCAB) License as provided for under Republic Act 4566 or the Contractors' Law to give assurance that qualified and quality service shall be provided.</i>
<b>QUERY # 1</b>	To clarify, what particular PCAB License Size Range and Category is you're looking for? Our company Integrated Power & Control Provider, Inc., have a PCAB License Small B Category A Specialty in Electrical Works, is that acceptable?
<b>RESPONSE</b>	The minimum required PCAB license is Category Small B.

<b>REQUIREMENT</b>	No. 5 of the Requirements of a Service Provider under Section VI of the Bidding Documents  <i>The brand of the Generator Set and ATS offered must be in the Philippine market for at least fifteen (15) years or preferably European or US brand.</i>
<b>QUERY # 2</b>	To clarify, if you can relax the brand of Generator Set and ATS for at least 5 years in the Philippine Market. Also, if country of origin like China or South Korea is acceptable for Generator Set only.

<b>RESPONSE</b>	After due consideration and in coordination with the End-user and TWG, the BAC decided to amend the requirement under No. 5 of Section VI. Schedule of Requirements of the Bidding Documents into:	
	<b>ORIGINAL</b>	<b>AMENDED</b>
	The brand of the Generator Set and ATS offered must be in the Philippine market for at least fifteen (15) years or preferably European or US brand.	The brand of the Generator Set and ATS offered must be in the Philippine market for <b><u>at least ten (10) years.</u></b>

<b>REQUIREMENT</b>	No. 6 of the Requirements of a Service Provider under Section VI of the Bidding Documents  <i>Certification from the manufacturer that the brand of the Generator Set and Automatic Transfer Switch being offered has been in the Philippine Market for the last fifteen years.</i>
<b>QUERY # 3</b>	To clarify, if Certification for ATS is issued only by the Authorized Distributor in the Philippines is acceptable?
<b>RESPONSE</b>	The certification issued by the authorized distributor specifically for the Generator Set and ATS is acceptable provided with a valid proof of authorization from the manufacturer.

2. Innovalite Inc.

<b>REQUIREMENT</b>	No. 5 of the Requirements of a Service Provider under Section VI of the Bidding Documents  <i>The brand of the Generator Set and ATS offered must be in the Philippine market for at least fifteen (15) years or preferably European or US brand.</i>
<b>QUERY # 1</b>	Since this equipment will be always OEM re-branding based of the Manufacturer principal supplier who will be producing the assembly of the equipment. We would like to clarify if the brand of the Engine and the Alternator is main consideration for Philippine Market or preferably European or US Brand.
<b>RESPONSE</b>	The requirement of at least ten (10) years in the Philippine market refers to the Generator Set and ATS which includes the engine, alternator and all other parts.

<b>REQUIREMENT</b>	For the Step-Load Acceptance Test to be conducted for the testing of the generating set
<b>QUERY # 2</b>	We would like to clarify if you required the contractor shall have mandatory requirement of In-house load bank Step loading test minimum rating 300KW?
<b>RESPONSE</b>	Yes.  The Test Load Acceptance Test is included in the Test Parameters as provided for in the Bid documents and is required to be performed by the winning bidder prior acceptance of delivery.

For the information and guidance of all concerned.

  
**DDG LINA C. SARMIENTO**  
 Chairperson  
 Bids and Awards Committee  
